

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 115

Dated: 10-02-2025

It is certified that an inspection team headed by .PRAMOD NAYAK, CHIEF CHEMIST.....

(Name of Officers with designation) from .STATE RESEARCH LABORATORY.....PHED

inspected the .WORLD WAY INTERNATIONAL SCHOOL, E-8 EXT., NEAR AAKRITI ECO CITY, ROHIT NAGAR PH-II, BHOPAL.....

(Name & Address of the school) on10-02-2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no.....115..... dated.....11-02-2025.....

of .STATE RESEARCH LABORATORY..... (PHED Lab) certified that the

.WORLD WAY INTERNATIONAL SCHOOL.....(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till10-02-2026.....

Signature with Seal:

Name : PRAMOD NAYAK.....

Designation : Chief Chemist.....

Name & Address of the Office / Department :

P.H.Eng. Dept. Bhopal

To

WORLD WAY INTERNATIONAL SCHOOL

E-8 EXT., NEAR AAKRITI ECO CITY, ROHIT NAGAR PH-II, BHOPAL

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Sushmita Datta
27/03/25
PRINCIPAL
World Way International School
E-8, Ext. World Way Road, Bhopal-462018
Ph. 0755-3291589, 4276668



TC-5722

State Research Laboratory, (SRL)
Public Health Engineering Department, P.H.E.D.
Shyamla Hills, Bhopal, 462002, Email-labbpl @ mp. nic. in, Phone-0755-4934796

Format No. SRL/PHED/BPL/4.1

ULR No.	T	C	5	7	2	2	2	5	0	0	0	0	0	0	3	2	5	F
---------	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Test Report

Nature of sample :- Drinking Water Sample / Others		Not sampled by State Research Lab		Unique Identification No.		727	
Sender's name and address		Sender's letter no.		-		Sender's letter Date	
TO, World Way International School E-8, Extension Near Aakriti Eco City Rohit Nagar Phase-2, Bhopal		SRL Ref. No		109		SRL receipt date	
		Date of analysis started		6/02/25		Date of analysis completed	
		Quantity Of sample		Ok			

Sample details

No.	Particulars of Samples
1.	R.O WATER SAMPLE

RESULTS

Field.. Testing		Discipline..Chemical	Group..Water		Sub. Group..Drinking Water				
No.	Characteristics/ Unit	test methods	BIS -10500:2012 Reaffirmed in Sep 2022		Results				
			Desirable Limit	Permissible Limit	1	-	-	-	-
1	2	3	4	5					
1	Colour in Hazen scale	-	5	15	NIL	-	-	-	-
2	Iron as Fe mg/l	APHA 23 rd edition, 3500-Fe B	1.0	1.0	0.12	-	-	-	-
3	Nitrate as NO3 mg/l	APHA 23 rd edition,4500 NO ₃ -B	45	45	6.14	-	-	-	-
4	Fluoride as F mg/l	APHA 23 rd edition,4500-F-C	1.0	1.5	0.25	-	-	-	-
5	Chloride as Cl mg/l	APHA 23 rd edition,4500 Cl-B	250	1000	20.0	-	-	-	-
6	Total Alkalinity as CaCO ₃ mg/l	APHA 23 rd edition, 2320 B	200	600	60.0	-	-	-	-
7	Calcium as Ca++ mg/l	APHA 23 rd edition, 3500 Ca-B	75	200	12.0	-	-	-	-
8	Magnesium as Mg++ mg/l	APHA 23 rd edition, 3500 Mg-	30	100	11.04	-	-	-	-
9	Sulphate as SO4 mg/l	BIS:3025 (Part -24)	200	400	18.56	-	-	-	-
10	pH pH Value at 25°C	APHA 23 rd edition 4500-H + B	6.5 to 8.5	6.5 to 8.5	7.35	-	-	-	-
11	Turbidity in NTU	APHA 23 rd edition, 2130 B	1.0	5.0	3.1	-	-	-	-
12	Total hardness as CaCO3 mg/l	APHA 23 rd edition, 2340 C	200	600	76.0	-	-	-	-
13	Conductivity at 25°C (S/m)	APHA 23 rd edition, 2510 B	-	-	255	-	-	-	-
14	TDS By meter mg/l	APHA 23 rd edition,2510 B	500	2000	150	-	-	-	-
15	Manganese as Mg/l	Mn APHA 23 rd edition 3500-mn-B	0.1	0.3	BDL	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.-
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 15 days from the date of issue of report.
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Reviewed By

PRAMOD NAYAK
CHIEF CHEMISTSTATE RESEARCH LABORATORY
P. H. E. DEPARTMENT BHOPAL

Issue No. 115 /S.R.L./PHED/BPL /2025 Issue Date 11/02/2025

Sushmita Seh
25/3/25
PRINCIPAL
World Way International School
E-8, Ext. World Way Road, Bhopal
Ph. 0755-3291589, 4276666

Test Report

Nature of sample :- Drinking Water Sample / Others	Not sampled by State Research Lab	Unique Identification No.	727-A ✓
Sender's name and address	Sender's letter no.	Sender's letter Date	6/02/25 ✓
TO,	SRL Ref. No	SRL receipt date	6/02/25 ✓
World Way International School	Date of analysis started	Date of analysis completed	10/02/25 ✓
E-8, Extension Near Aakriti Eco	Quantity Of sample		
City Rohit Nagar Phase-2, Bhopal	Ok		

Sample details

No.	Particulars of Samples
1.	R.O WATER SAMPLE

RESULTS

Field.. Testing	Discipline..Chemical	Group..Water	Sub. Group..Drinking Water
No.	Characteristics/ Unit	test methods	BIS -10500:2012 Reaffirmed in Feb. 2021
			Desirable Limit
			Permissible Limit
1	2	3	4
			5
1	Temperature in degree C	-	--
2	Odour	-	Objectionable
3	Phenolphthalein Alkalinity as caCO ₃ mg/l	APHA 23 rd edition, 2320 B	-
4	Sodium as Na mg/l	APHA 23 rd edition, 3500 - Na B	-
5	Potassium as K mg/l	APHA 23 rd edition, 3500 - K B	-
6	Dissolved Oxygen mg/l	-	-
7	Chemical Oxygen Demand (COD)mg/l	-	-
8	Biological Oxygen Demand (BOD) mg/l	-	-
9	Jar Test for Alum & lime dosing fixation mg/l	-	-
10	Purity of Alum	-	-
11	Purity of Lime	-	-
12	Purity of Bleaching	-	-
13	Chlorine test Demand	-	-
14	Total coliform per 100 ml	APHA 23 rd edition, 9211 B	NIL for treated water and water in distribution system
15	Faecal Coliform (TTC) per 100 ml	APHA 23 rd edition, 9211 B	NIL

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 15 days from the date of issue of report.
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. This report show only Non NABL parameters.

Reviewed By

Issue No. 115 /S.R.L./PHED/BPL /2025 Issue Date 11/02

(PRAMOD NAYAK)
CHIEF CHEMIST
STATE RESEARCH LABORATORY
P.H.E. DEPARTMENT BHOPAL
World Way International School
E-8, Ext. World Way Road, Bhopal-30
Ph. 0755-3291589, 4276668